



Product Service

# CERTIFICATE

No. Z2 14 06 84724 010

**Holder of Certificate:** **Zhejiang BLD Solar Technology Co., Ltd.**

Qinggang Technological Ind. Zone  
317606 Yuhuan, Zhejiang  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:**

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Poly-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:**

704061342705-01

**Date,** 2014-06-24

( Zhulin Zhang )

Page 1 of 2





Product Service

**CERTIFICATE****No. Z2 14 06 84724 010****Model(s):**

BLD250-72P, BLD255-72P, BLD260-72P, BLD265-72P,  
 BLD270-72P, BLD275-72P, BLD280-72P, BLD285-72P,  
 BLD290-72P, BLD295-72P, BLD300-72P, BLD305-72P,  
 BLD310-72P, BLD210-60P, BLD215-60P, BLD220-60P,  
 BLD225-60P, BLD230-60P, BLD235-60P, BLD240-60P,  
 BLD245-60P, BLD250-60P, BLD255-60P, BLD260-60P,  
 BLD185-54P, BLD190-54P, BLD195-54P, BLD200-54P,  
 BLD205-54P, BLD210-54P, BLD215-54P, BLD220-54P,  
 BLD225-54P, BLD230-54P, BLD165-48P, BLD170-48P,  
 BLD175-48P, BLD180-48P, BLD185-48P, BLD190-48P,  
 BLD195-48P, BLD200-48P, BLD205-48P, BLD125-36P,  
 BLD130-36P, BLD135-36P, BLD140-36P, BLD145-36P,  
 BLD150-36P, BLD155-36P.

**Parameters:**

Rated Output Power  
 at STC:

250 W, 255 W, 260 W, 265 W,  
 270 W, 275 W, 280 W, 285 W,  
 290 W, 295 W, 300 W, 305 W,  
 310 W, 210 W, 215 W, 220 W,  
 225 W, 230 W, 235 W, 240 W,  
 245 W, 250 W, 255 W, 260 W,  
 185 W, 190 W, 195 W, 200 W,  
 205 W, 210 W, 215 W, 220 W,  
 225 W, 230 W, 165 W, 170 W,  
 175 W, 180 W, 185 W, 190 W,  
 195 W, 200 W, 205 W, 125 W,  
 130 W, 135 W, 140 W, 145 W,  
 150 W, 155 W.

Construction:

Framed, with Junction box,  
 Cable and Connectors.

Test Laboratory:

Yangzhou Opto-Electrical  
 Products Testing Institute,  
 No. 10 West Kaifa Road, Yangzhou,  
 225009 Jiangsu, P. R. China.

Application Class:

Class A

Maximum System Voltage:

1000 V DC

Fire Safety Class:

Class C

**Tested  
according to:**

IEC 61215:2005  
 EN 61215:2005  
 IEC 61730-1:2004  
 EN 61730-1:2007  
 IEC 61730-2:2004  
 EN 61730-2:2007

**Production  
Facility(ies):**

84724

Page 2 of 2